



LIMIT SW DEVELOPMENT		
EBASCO SYMBOL	CONT.	VALVE OPNG. %
		0 100
bo	1-2	*
ac	3-4	*
bo	5-6	*
ac	7-8	*
ao	9-10	*
bc	11-12	*
ao	13-14	*
bc	15-16	*
a %	17-18	*
b %	19-20	*
a %	21-22	*
b %	23-24	*
a %	25-26	*
b %	27-28	*
a %	29-30	*
b %	31-32	*
tc	35-36	OPENS ON OVERLOAD ON CLOSE STROKE *
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE *

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. A.M. CH. V. ALKSNINIS DATE MAY 11, 1978		APPROVED  DATE MAY 11, 1978		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM HYDROGEN PURGE TRAIN B CTMT ISCL VA 2PV-B1105B		WPPS-3240 D-5001 SHEET 2717	
------------------------------------------------------------------------------------------------	--	-----------------------------------	--	----------------------------------------------------------------------------------------------------------------------------------------------------	--	-----------------------------------	--

11-74 08050



AIDS

8303100294

