



SWITCH	EIASCO SYMBOL	LIMIT SW DEVELOPMENT		CWD SH.
		CONT.	VALVE OPNG. %	
		O	100	
LSO-1	bo	5-12		*
LSC-2	ac	8-10		*
LSO-2	bo	8-9		*
LSC-1	ac	13-11		
LSO-1	ao	5-7		
LSC-2	bc	8-15		
LSO-2	ao	8-16		
LSC-1	bc	13-14		(*)
LSA-1	sc	17-18		
LSB-1	bo	23-24		
LSA-2	ac	20-21		(*)
LSE-2	bo	26-27		
LSA-1	bc	17-19		
LSB-1	ao	23-25		(*)
LSA-2	bc	20-22		
LSB-2	ao	26-28		
TSC	1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
TSD	1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

--- CONT. CLOSED * THIS SHEET

PRC APERTURE CARD

5 4 3 1-14-32 2 10-15-81 1 1-25-80 REV DATE BY APPROVED		EBASCO SERVICES INCORPORATED DIV. CONTROL DR. RK CH. V. ALKSNINIS DATE MAY 11, 1978	APPROVED <i>D.D. Price</i> <i>W.A. ...</i>	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECT NO 3 & 5 CONTROL WIRING DIAGRAM HYDROGEN PURGE TRAIN B CTMT ISOL VA 2P4-B109SA	WPPS-3240 D-6001 SHEET 2718
--	--	--	--	--	-----------------------------------

RIDS

8303100296

