



LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG. %	
		O	100
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		*
b %	19-20		*
a %	21-22		*
b %	23-24		*
b %	25-26		*
a %	27-28		*
b %	29-30		*
a %	31-32		*
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

— CONT. CLOSED \* THIS SHEET

PRC APERTURE CARD

<b>NUCLEAR SAFETY RELATED</b>		<b>WPPSS QUALITY CLASS I</b>	
<b>EDASCO SERVICES INCORPORATED</b>			
REV. DATE BY APPROVED	DATE MAY 11, 1978	DIV. CONTROL DR. A.M. CH. VALKSNINIS APPROVED <i>[Signature]</i>	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM CTMT HYDROGEN PURGE/VENT MAKE-UP ISOL V2 FV E0195A
			<b>WPPS-3240</b> <b>D-6001</b> <b>REVISION 2719</b>



RIDS

8303100298

