



NOTES  
 1. FIELD TO RECONNECT AS SHOWN.  
 2. TERMINATION INFORMATION TO BE PROVIDED BY 224 CONTRACTOR.

PRC APERTURE CARD

CONTACT	POSITION FRONT VIEW			CWD
	STOP	AUTO	START	
1	X		*	
2		X	*	
3			X	
4		X	X	

SPRING RETURN TO AUTO \* THIS SHEET

CONTACT	CWD
17	a
19	b *
21	a *
23	b *
25	a *
27	b *
29	a *
31	b *

CONTACT	CWD
331	332
333	334
335	336
337	338
339	340
341	342
343	344
345	346 *
A1	B1 *
A11	B11 *
A12	B12 *
C1	D1 *

(CELL SW SHOWN IN BKR CONNECTED POSITION)

7-14-81 RVP V.N. 601 3-20-80 LVT H.C. 201 12-15-79 LVT H.C. 201 6-27-79 LVT H.C. 201 11-2-78 KD H.C. 201		<b>EBASCO SERVICES INCORPORATED</b> DIV. CONTROL DR. A.M. CH. R. GHATAK DATE AUG 31, 1976		APPROVED <i>R. Ghatak</i> 401 PAVELS A 19/16		<b>WASHINGTON PUBLIC POWER SUPPLY SYSTEM</b> NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM REACTOR SUPPORT AND CAVITY COOLING FAN E-1A		<b>WPPSS-3240</b> <b>D-6001</b> <b>SHEET 2758</b>	
--	--	--	--	--	--	--	--	---	--

RIDS

8303100436

