



NOTE
I. JUMPER BY FIELD

LIMIT SW DEVELOPMENT			
ERASCO SYMBOL	CONT.	VALVE OFFNO. %	CMD SH.
bo	1-2		
bc	3-4		
b9	5-6		
bc	7-8		
bc	9-10		
b2	11-12		
bc	13-14		
bc	15-16		
b2	17-18		
b2	19-20		
b2	21-22		
b2	23-24		
b2	25-26		
b2	27-28		
b2	29-30		
b2	31-32		
1c	33-36	OPENS ON OVERLOAD ON CLOSE STROKE	
1o	45-48	OPENS ON OVERLOAD ON OPEN STROKE	

CONT. CLOSED THIS SHEET

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

ERASCO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM		WPPS-924C D-8001 JUN 28 1978
DIV. CONTROL OP. A.M. CH. VALKSNINIS		APPROVED [Signature]		
DATE JUNE 16, 1978		NUCLEAR PROJECTS NO. 3 & 8 CONTROL WIRING DIAGRAM ANNULUS SUPPLY ISOL VA 2PV-B1015B		

RIDS

8303100496

