



LIMIT SW DEVELOPMENT

SYMBOL	CONT.	VALVE OPNG. %	CHD SH.
bc	1-2		
bc	3-4		
bc	5-6		
bc	7-8		
bc	9-10		
bc	11-12		
bc	13-14		
bc	15-16		
a %	17-18		
b %	19-20		
a %	21-22		
b %	23-24		
a %	25-26		
b %	27-28		
a %	29-30		
b %	31-32		
tc	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE	

CONT. CLOSED THIS SHEET

PRC APERTURE CARD

480V MCC A 322-SA COMPT 9M

(-11493) MOV LIMIT SW'S

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. A.M. CH. V. ALKSNINIS DATE JUNE 16, 1978		APPROVED [Signature]		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NOS 3 & 5 CONTROL WIRING DIAGRAM SBVS B DECAY HEAT REMOVAL VA 2EV-0325A		WPPS-3240 D-8001 REVIT 2806	
---	--	-------------------------	--	---	--	-----------------------------------	--

PLATE 18 1105 11-03 40664

RIDS

8303/00504

