



LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPEN %	CWD SH.
		0	
		100	
bo	1-2		*
ac	3-4		*
bo	5-6		*
ac	7-8		*
ao	9-10		*
bc	11-12		*
ao	13-14		*
bc	15-16		*
a %	17-18		
b %	19-20		
a %	21-22		
b %	23-24		
a %	25-26		
a %	27-28		
b %	29-30		
a %	31-32		
1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1a	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

PRC APERTURE CARD

- NOTES
- FOR TRANSFER SWITCH TS DEVELOPMENT SEE SH. 2111.
 - CONTACT CLOSING ON HIGH RADIATION.
 - CONTACT CLOSING ON RAD MONITOR FAILURE.

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. R.K. CH. V. ALKSNINIS DATE MAY 11, 1978		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM FUEL HANDLING BUILDING DISCH. VALVE 2PV-B0075A		WPPSS QUALITY CLASS I WPPS-3240 D-6001 SHEET 2828
--	--	---	--	--

KIDS

8303100506

