



LIMIT SW DEVELOPMENT			
EBASCO SYMBOL	CONT.	VALVE OPNG %	CWD SH.
		0	
		100	
bc	1-2		*
cc	3-4		*
bc	5-6		*
cc	7-8		*
oo	9-10		*
bc	11-12		*
oo	13-14		*
bc	15-16		*
a %	17-18		
b %	19-20		
a %	21-22		
b %	23-24		
b %	25-26		
a %	27-28		
b %	29-30		
a %	31-32		
* 1c	35-36	OPENS ON OVERLOAD ON CLOSE STROKE	*
1o	45-46	OPENS ON OVERLOAD ON OPEN STROKE	*

- NOTES
- FOR TRANSFER SWITCH TS DEVELOPMENT SEE SH. 2112
 - CONTACT CLOSURES ON HIGH RADIATION
 - CONTACT CLOSURES ON RAD MONITOR FAILURE

EBASCO SERVICES INCORPORATED			
REV.	DATE	BY	APPROVED
1	12-29-81	EM	NA
2	5-23-80	SK	NA
DATE MAY 11, 1978		APPROVED	

PRO APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO. 3 & 5
 CONTROL WIRING DIAGRAM

FUEL HANDLING BUILDING DISCH VALVE 2FV-B1075B

WPPSS-324C
 D-6001
 SHEET 2029

RIDS

8303100517

