



NOTE:  
1. FOR TRANSFER SWITCH  
TS DEVELOPMENT SEE SP.2112

LIMIT SW DEVELOPMENT				
EBASCO SYMBOL	CONT.	VALVE OPNG. %		CWD SH.
		0	100	
bo	1-2			*
ac	3-4			*
bo	5-6			*
ac	7-8			*
co	9-10			*
bc	11-12			*
co	13-14			*
bc	15-16			*
a %	17-18			
b %	19-20			
a %	21-22			
b %	23-24			
b %	25-26			
a %	27-28			
b %	29-30			
a %	31-32			
tc	35-36	OPENS ON OVERLOAD ON CLOSE STROKE		*
to	45-46	OPENS ON OVERLOAD ON OPEN STROKE		*

CONT. CLOSED \* THIS SHEET

APERTURE CARD

**NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I**

EBASCO SERVICES INCORPORATED DIV. CONTROL DR. R.K. CH. V. ALKSNINIS DATE JUNE 8, 1978		APPROVED 		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM ECCS AREA EXH. CLEAN-UP UNIT - SUCTION VALVE 2PV-D155E		WPPS-324C D-6001 SHEET 2038	
--	--	--------------	--	---	--	-----------------------------------	--



RIDS

8303100530

