

CONTAINMENT SUMP B ISOLATION VALVE  
 CS OPEN/O-RIDE  
 AUTO  
 VALVE CLOSE  
 SPRING RETURN TO AUTO-KEYLOCK  
 KEY REMOVAL AUTO ONLY

RAS "B"

CONT. SPRAY PUMP B MIN. FLOW VALVE  
 CS OPEN  
 AUTO  
 VALVE CLOSE/O-RIDE  
 SPRING RETURN TO AUTO-KEYLOCK  
 KEY REMOVAL AUTO ONLY

CONTAINMENT SPRAY ISOLATION VALVE  
 CS OPEN/O-RIDE  
 AUTO  
 VALVE CLOSE  
 SPRING RETURN TO AUTO-KEYLOCK  
 KEY REMOVAL AUTO ONLY

CSAS "B"

\* LPSI PUMP 2 DISCH. SCHX 2 CROSS CONN. VALVE  
 PB OPEN  
 VALVE CLOSE

SI VALVE SELECTOR SWITCH  
 SS LOCK  
 UNLOCK  
 KEYLOCK - KEY REMOVAL  
 IN LOCK ONLY

\* SCHX 2 OUT TO LPSI HDR 2 CROSS CONN. VALVE  
 PB OPEN  
 VALVE CLOSE

\* FOR TYPICAL C.R. TO RSP TRANSFER SEE SH. 153B

CONTAINMENT SUMP B ISOLATION VALVE  
 2CS-B002 5B (51-676)  
 OPEN  
 VALVE CLOSE  
 IL G  
 IL R

CONTAINMENT SPRAY PUMP B MIN. FLOW VALVE  
 2CS-VQ 006 5BR (51-665)  
 OPEN  
 VALVE CLOSE  
 IL G  
 IL R

CONTAINMENT SPRAY ISOLATION VALVE  
 2CS-VS092 5B (51-671)  
 OPEN  
 VALVE CLOSE  
 IL G  
 IL R

LPSI PUMP 2 DISCH. SCHX 2 CROSS CONN. VALVE  
 2CS-VS018 5BR (51-694)  
 OPEN  
 VALVE CLOSE  
 IL G  
 IL R

SCHX 2 OUT TO LPSI HDR 2 CROSS CONN. VALVE  
 2CS-VS 022 5BR (51-696)  
 OPEN  
 VALVE CLOSE  
 IL G  
 IL R

PRO APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EBASCO SERVICES INCORPORATED				WASHINGTON PUBLIC POWER SUPPLY SYSTEM		WPPSS-3240	
DIV. INSTRUMENTATION DR. EF				NUCLEAR PROJECT NO 3 & 5		D6080	
CH. A. JUGO				INSTRUMENT SCHEMATIC - LOGIC DIAGRAM		SHEET 126 F	
DATE JAN. 31. 1979				CONTAINMENT SPRAY SYSTEM			
5							
4							
3							
2							
1							
REV.	DATE	BY	APPROVED				

