

CONTAINMENT SS
 SPRAY VALVE LOCK
 SELECTOR SW UNLOCK
 KEYLOCK-KEY REMOVAL
 IN LOCK ONLY

* CONTAINMENT PB
 SPRAY PUMP B OPEN
 DISCH. VALVE CLOSE

* SCHX 2 TO CONT. SPRAY HDR 2 ISOL. VALVE
 PB OPEN
 VALVE CLOSE

* SCHX 2 BYPASS VALVE
 PB OPEN
 VALVE CLOSE

CONTAINMENT CS
 SPRAY PUMP B OPEN
 FLOW CONTROL VALVE NORMAL
 VALVE CLOSE
 SPRING RETURN TO NORM-KEYLOCK
 KEY REMOVAL IN NORMAL ONLY
 (INCHING CONTROL)

CONTAINMENT CS
 SPRAY PUMP B START/O-RIDE
 AUTO
 STOP

CSAS 'B'

CONTAINMENT SPRAY PUMP B DISCH. VALVE
 2CS-VS08 SDR (SI-689)
 OPEN
 CLOSE

SCHX 2 TO CONTAINMENT SPRAY HDR 2 ISOL. VA.
 2CS-VS024 SBR (SI-695)
 OPEN
 CLOSE

SCHX 2 BYPASS VALVE
 2CS-VS080 SBR (SI-693)
 OPEN
 CLOSE

CONTAINMENT SPRAY PUMP B FLOW CNTRL VALVE
 2CS-F004 SBR (SI-679)
 OPEN
 CLOSE

CONTAINMENT SPRAY PUMP B
 START
 STOP

* FOR TYPICAL C.R. TO RSP
 TRANSFER SEE LOGIC SH.153B

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

5									
4									
3									
2									
1									
REV	DATE	BY	APPROVED	EBASCO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM		WPFS-3240	
				DIV. INSTRUMENTATION DR. EF		NUCLEAR PROJECT NO 3 & 5		D6080	
				CH. A. JUGO		INSTRUMENT SCHEMATIC - LOGIC DIAGRAM		SHEET 125 F.	
				DATE JAN. 31, 1979		CONTAINMENT SPRAY SYSTEM			

17

11

8.5

8.5

11

17

17

11

8.5

8.5

11

17

RIDS

8303110508

