



S.H.P. WASTE TANK B INLET VALVE X021
 DEENERGIZE TO OPEN
 ENERGIZE TO CLOSE
 SPRING RETURN TO AUTO FROM OPEN MAINTAIN IN CLOSE

S.H.P. WASTE TANK B OUTLET VALVE X025
 OPEN
 NORM
 CLOSE
 ENERGIZE TO OPEN
 DEENERGIZE TO CLOSE

S.H.P. WASTE PUMP B
 START
 NORM
 STOP
 START
 STOP

S.H.P. WASTE PUMP B RECIRCULATION VALVE X028
 OPEN
 CLOSED
 IL G
 IL R

PRC APERTURE CARD

NOTE:
 1- ALL SWITCHES ARE SPRING RETURN TO CENTER POSITION UNLESS OTHERWISE NOTED

<table border="1"> <tr><td>5</td><td></td><td></td><td></td></tr> <tr><td>4</td><td></td><td></td><td></td></tr> <tr><td>3</td><td></td><td></td><td></td></tr> <tr><td>2</td><td>3-10-80</td><td>RFD</td><td>W. P. H. / J. P. G.</td></tr> <tr><td>1</td><td>1-22-79</td><td>RPF</td><td>J. P. G.</td></tr> </table>				5				4				3				2	3-10-80	RFD	W. P. H. / J. P. G.	1	1-22-79	RPF	J. P. G.	EBASCO SERVICES INCORPORATED DIV. ENGINEERING DR. BM CH. J. PAGLIANTI DATE APRIL 20, 1976		APPROVED <i>R. A. ...</i> J. P. H. / J. W. D.		WPPSS QUALITY CLASS II WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECT NO 3 & 5 INSTRUMENT SCHEMATIC - LOGIC DIAGRAM SECONDARY HIGH PURITY WASTE TANK B		WPPS-3240 D6080 SHEET 252 B	
5																															
4																															
3																															
2	3-10-80	RFD	W. P. H. / J. P. G.																												
1	1-22-79	RPF	J. P. G.																												

RIDS

8303110624

