



NOTES

- FOR TRANSFER SWITCH TS12-2 DEVELOPMENT SEE SH. 2110.
- INTERBAY WIRING TO BE ROUTED IN METALLIC CONDUIT & SEALED WITH FIREPROOF MATERIAL BY FIELD.
- FIELD TO ADD JUMPER.
- FIELD TO WIRE CONTACT.

LEGEND

* — THIS SHEET

5. FIELD TO RECONNECT WIRE AS SHOWN

EABASCO SERVICES INCORPORATED			
DIV. CONTROL DR. C. KIM		APPROVED	
CH. A. R. RAO		<i>[Signature]</i>	
DATE APRIL 22, 1980		<i>[Signature]</i>	
REV.	DATE	BY	APPROVED
1	5-19-82	FW	<i>[Signature]</i>
2	4-26-81	JP	<i>[Signature]</i>

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

WASHINGTON PUBLIC POWER SUPPLY SYSTEM
 NUCLEAR PROJECTS NO. 3 & 5
 CONTROL WIRING DIAGRAM
 TURB DRIVEN AUX FDW PUMP A
 T&T VALVE

WPPS-3240
 D-6001
 SHEET 1173

11
11
5.8
10
10

11
11
5.8
8.5
11
17

RIDS

8303160133

