



LEGEND
* THIS SHEET

NOTE
1. INTERBAY WIRING TO BE ROUTED IN METALLIC CONDUIT & SEALED WITH FIREPROOF MATERIAL BY FIELD.

PRC
APERTURE
CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

EASCO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM	
DIV. CONTROL DR. ΔAN		NUCLEAR PROJECTS NO. 3 & 5	
CH. V. ALKSNINIS		CONTROL WIRING DIAGRAM	
DATE JUN. 22, 1977		EMERGENCY DIESEL GENERATOR B-5B	
REV. DATE BY APPROVED		SEQUENTIAL LOADING SH. 5	
		WPPS-3240	
		D-6001	
		SHEET 0631	

RIDS

8303/60/88

