



86B/83SB (HAND RESET)

CONTACTS HANDLE END	FUNCTION	CWD
A1	DSL GEN BKR PERMISSIVE	0614
A12	DSL GEN BKR TRIP	0614
A11	BUS B3-SB TIE BKR PERMISSIVE	0439
C1	BUS B3-SB TIE BKR TRIP	0439
C12	ANNUNCIATION	*
C11	BUS DIFF RELAY φ A	0421
E1	BYP STATUS PNL	*
E12	BUS DIFF RELAY φ B	0421
E11	LOCAL ANNUNCIATION	0620
A5	BUS DIFF RELAY φ C	0421
A6	BUS DIFF RELAY φ C	0421
A7	BUS DIFF RELAY φ C	0421
C5	SPARE	*
C6	SPARE	*
C7	SPARE	*
E5	SPARE	*
E6	SPARE	*
E7	SPARE	*

86TB/83SB (HAND RESET)

CONTACTS HANDLE END	FUNCTION	CWD
A1	BUS B3-SB TIE BKR PERMISSIVE	0439
A12	BUS B3-SB TIE BKR TRIP	0439
A11	ANNUNCIATION	*
C1	BUS B2 TIE BKR TRIP	0276
C12	BUS B2 TIE BKR PERMISSIVE	0276
C11	SPARE	*
E1	SPARE	*
E12	SPARE	*
E11	SPARE	*
A5	SPARE	*
A6	SPARE	*
A7	86TB/B3-SB	*
C5	SPARE	*
C6	SPARE	*
C7	SPARE	*
E5	SPARE	*
E6	SPARE	*
E7	SPARE	*

NOTES
 1 WHITE INDICATING LIGHTS TO BE PHYSICALLY WIRED TO THE END OF TRIP CIRCUITS.
 2 RELAYS 74B AND 74T TO BE PHYSICALLY WIRED TO THE END OF THEIR RESPECTIVE CIRCUITS.

LEGEND * THIS SHEET

PRO APERTURE GARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I

3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100	EBASCO SERVICES INCORPORATED DIV. CONTROL DR. LVT CH. M. SHEVADE DATE SEP 20, 1976	APPROVED WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM 4, 16KV BUS B3-SB AND TIE DIFFERENTIAL LOCKOUT RELAYS	WPPSS-3240 D-6001 SHEET 0422
--	--	--	------------------------------------

RIDS

8303160509

