



PRC
APERTURE
CARD

- NOTES:
1. ALARMS WHEN PZR PRESSURE IS >700 PSIG AND SI TANK PRESSURE IS <600 PSIG.
 2. N/C CONTACT OPENS WHEN DECREASING RCS PRESS IS <400 PSIA AND CLOSSES WHEN INCREASING RCS PRESS IS >500 PSIA.
 3. N/O CONTACT OPENS WHEN THE RCS PRESS IS >500 PSIA & CLOSSES WHEN THE RCS PRESS IS <400 PSIA.
 4. N/C CONTACT OPENS WHEN DECREASING RCS PRESS IS <415 PSIA AND CLOSSES WHEN INCREASING RCS PRESS IS >500 PSIA.
 5. N/O CONTACT OPENS WHEN THE RCS PRESS IS >500 PSIA & CLOSSES WHEN THE RCS PRESS IS <415 PSIA.

REF:
B-8973-416-109-03 SH. 1 (3240-2195)

7-15-82		EVT		V.A.		NUCLEAR SAFETY RELATED		WPPSS QUALITY CLASS 1	
6-25-82		EVT		V.A.		EBASCO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM	
12-14-81		EVT		V.A.		DIV. CONTROL DR. R. GHATAK		NUCLEAR PROJECTS NO. 3 & 5	
1-12-81		EVT		V.A.		CH. E. OVALLE		CONTROL WIRING DIAGRAM	
10-13-78		AS		CP		DATE APR 15, 1977		PRESSURIZER PRESSURE MEAS. CH. P-103	
REV.		DATE		BY		APPROVED		WPPSS-3240 D-6001	

MADE TO ORDER 11-73 40823

RIDS

8303170065

