



- NOTES:
1. N/C CONTACT OPENS WHEN DECREASING RCS PRESS IS < 400 PSIA AND CLOSES WHEN INCREASING RCS PRESS IS > 500 PSIA.
  2. N/O CONTACT OPENS WHEN THE RCS PRESS IS > 500 PSIA & CLOSES WHEN THE RCS PRESS IS < 400 PSIA.

REF:  
B-3973-416-109-02 SH. 3 (3240-2197)

PRO  
APERTURE  
CARD

NUCLEAR SAFETY RELATED				WPSS QUALITY CLASS I			
EBASCO SERVICES INCORPORATED				WASHINGTON PUBLIC POWER SUPPLY SYSTEM			
DIV. CONTROL DR. B. GHATAK				APPROVED			
CH. E. O'VALLI				WPPS-3240			
DATE APR 15 1977				NUCLEAR PROJECTS NO. 3 & 5			
REV. DATE BY APPROVED				CONTROL WIRING DIAGRAM			
				PRESSURIZER PRESSURE			
				MEAS CH. P-105			
				SHEET 1626			

RIDS

8303170069

