



- NOTES:
1. N/O CONTACT OPENS WHEN DECREASING RCS PRESS IS < 400 PSIA AND CLOSSES WHEN INCREASING RCS PRESS IS > 500 PSIA.
 2. N/O CONTACT OPENS WHEN THE RCS PRESS IS > 500 PSIA & CLOSSES WHEN THE RCS PRESS IS < 400 PSIA.

PRC
APERTURE
CARD

REF:
B-8973-416-109-02, SH. 3 (3240-2197)

5		NUCLEAR SAFETY RELATED		WPPSS QUALITY CLASS 1	
4		EBASCO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM	
7-2-82		DIV. CONTROL DR. R. GHATAK		NUCLEAR PROJECTS NO. 3 & 5	
1-12-81		CH. E. OVALLE		CONTROL WIRING DIAGRAM	
10-13-75		DATE APR 15, 1977		PRESSURIZER PRESSURE	
REV. DATE BY APPROVED		APPROVED		MEAS. CH. P-106	
		WPPSS-3240		D-6001	
		SHEET 1627		R	

RIDS

8303170070

