



CONTACT	POSITION FRONT VIEW			CWD
	STOP	NORM	START	
1		X	X	
2			X	
3	X			*
4			X	*

  

CONTACT	POSITION FRONT VIEW			CWD
	OPEN	NORM		
A11-B11		X		
A12-B12	X			*
A1-B1			X	
A5-B5			X	
A6-B6	X			
A7-B7			X	

SPRING RETURN TO NORMAL FROM START, MAINTAINED IN STOP \* THIS SHEET

UPPER AUX TERM CAB NEAR MTR

VIBRATION SW N-152 (-4676)

RESET

NOTE

- FOR "CST" SWITCH DEVELOPMENT SEE SH. 0236
- FIELD TO WIRE

REV	DATE	BY	APPROVED
5	6-22-82	RJP	VA
4	12-17-81	RJP	VA
3	9-4-81	RJP	VA
2	2-21-79	VA	VA

EBASCO SERVICES INCORPORATED

DIV. CONTROL DR. LVT

CH. E. DUVILLE

DATE

APPROVED

Wallach

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

NUCLEAR PROJECTS NO. 3 & 5

CONTROL WIRING DIAGRAM

REACTOR COOLANT PUMP 1A

WPPS-3240

D-6000

SHEET 1640

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I - II

**RIDS**

8303170074

