



- NOTES
1. FOR REF DWGS SEE SH.1700.
 2. ESF TRIPS SHALL BE CONNECTED IN SERIES FOR ANNUNCIATION AND ONE REPEAT CONTACT PER EACH ESF ALARM FOR COMPUTER INPUTS.
 3. SEE NOTES 3 & 4 ON SH.1780 FOR RPS & ESF MULTIPLE INPUT & OUTPUT BLOCK DIAG.

PRC APERTURE CARD

NUCLEAR SAFETY RELATED WPPSS QUALITY CLASS I & II

3 4 5-8-81 12-11-78 REV. DATE BY APPROVED		EBASCO SERVICES INCORPORATED DIV. CONTROL DR. AAN CH. V. ALKSNINIS DATE AUG. 25, 1977	APPROVED <i>(Signature)</i> WPPSS	WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 CONTROL WIRING DIAGRAM PPS CHANNEL B ALARMS (TRIPS & PRETRIPS)	WPPSS-3240 D-6001 SHEET 1781
---	--	--	---	---	------------------------------------

RIDS

8303210089

