



- NOTES
- FOR REF DWGS SEE SH. 1700.
 - ESF TRIPS SHALL BE CONNECTED IN SERIES FOR ANNUNCIATION AND ONE REPEAT CONTACT PER EACH ESF ALARM FOR COMPUTER INPUTS.
 - SEE NOTES 3 & 4 ON SH. 1780 FOR BLOCK DIAG.

PRC
APERTURE
CARD

5		EBASCO SERVICES INCORPORATED		WASHINGTON PUBLIC POWER SUPPLY SYSTEM		WPPS-3240	
4		DIV. CONTROL DR. AAN		NUCLEAR PROJECTS NO. 3 & 5		0-6001	
3		CH. VALKSNINIS		CONTROL WIRING DIAGRAM		SWEL 1783	
2		DATE AUG. 25, 1977		PPS CHANNEL D			
1		APPROVED		ALARMS (TRIPS & PRETRIPS)			

1978 11-74 0092

RIDS

8303210096

