



- NOTE:
- FOR NOTES AND REFERENCE DRAWINGS SEE DRAWING 61721-2095-24
 - RESET DIFFERENTIAL IS ADJUSTED SLIGHTLY GREATER THAN THE DIFFERENTIAL BETWEEN LLS HIGH AND LOW REACTOR PRESSURES
 - REFER TO DWG 61721-2095-38 FOR LOW LOW SET DESIGN SCHEMATIC

8303859102

Do Not Construct From This Print FOR INFORMATION ONLY

PRC APERTURE CARD

NUCLEAR SAFETY RELATED ITEMS ARE SHOWN ON THIS DRAWING (FOR SAFETY CLASSIFICATION SEE PIPING, EQUIPMENT, VALVE OR INSTRUMENT LISTS.)

GENERAL ELECTRIC

The Detroit Edison Co. Engineering

REV.	DATE	BY	CHKD.	DESCRIPTION
1	11/20/83	W. J. HARRIS	W. J. HARRIS	ISSUED FOR CONSTRUCTION
2	12/23/83	W. J. HARRIS	W. J. HARRIS	TESTABILITY MODIFICATION

APPROVED BY: <i>[Signature]</i>	DATE: 11/20/83
DESIGN: W. J. HARRIS	CHECKED: W. J. HARRIS
REVISIONS: 1, 2	SCALE: AS SHOWN
TITLE: SCHEMATIC DIAGRAM NUCLEAR BOILER PROCESS INSTRUMENT A & B CIRCUITS - PART I TESTABILITY MODIFICATION	DRAWING NUMBER: 61721-2095-37

RIDS

8303250102

