

24.02 (CONT'D)

TABLE C (cont'd)

CABLE B/M NO.	CLASS	CABLE DESCRIPTION	OD (INCH)	AREA (IN ²)	MINIMUM BENDING RADIUS R
E90-07	L	RG 62A/U	0.45	0.16	6.5
D99-01	L	16TP #18	0.67	0.36	16
02	L	TRIX	0.25	0.05	6
03	L	TRIX	0.25	0.05	6
06	L	TRIX	0.50	0.20	12
11	L	30/c X LP/1R/02	0.39	0.12	9
12	L	30/c XLP/1R (59)	0.39	0.12	9
14	L	4/c #16	0.50	0.20	12
15	L	RG 59B/U	0.67	0.35	16
16	L	1PR #18	0.35	0.10	8.5
17	L	RG 59B	0.25	0.05	6
21	L	BELDEN #8770	0.24	0.04	6
22	L	BELDEN #8722	0.23	0.04	6
23	L	BELDEN #8786	0.24	0.04	6
24	L	8 #18 7/.0152/05	0.66	0.34	16
25	L	95 ohm COAXIAL	0.16	0.02	4

INCHES
0 1 2 3 4 5

PRC
APERTURE
CARD

NUCLEAR SAFETY RELATED | WPPSS QUALITY CLASS II & G

5							
4							
3							
2							
1							
REV.	DATE	BY	APPROVED	EBASCO SERVICES INCORPORATED DIV. ELEC. DR. D.H. CH. R. Thomas DATE FEB. 17, 1982		WASHINGTON PUBLIC POWER SUPPLY SYSTEM NUCLEAR PROJECTS NO. 3 & 5 BOX DETAILS NOTES	
				APPROVED <i>J.C. Gonzalez</i> <i>R. Montano</i>		WPPS-3240 D-5033 SHEET 25	

17"

11"

8.5"

8.5"

11"

17"

17"

11"

8.5"

8.5"

11"

17"

RIDS

8303290681

