



WPPS-3240-G-5336

SECTION J-J (G-5314, G7)
SCALE: 1/4" = 1'-0"

SECTION K-K (G-531201 (13))
SCALE: 1/4" = 1'-0"

DETAIL 'A' (G-5314, F7)
PRESSURIZER ROOM EMBEDDED CONDUITS
SCALE: 3/8" = 1'-0"

NOTES:
1. FOR GENERAL NOTES SYMBOLS & REFERENCE DWG'S SEE DWG D-5023
2. ALL EMBEDDED CONDUIT BENDS IN PRESSURIZER ROOM FLOOR SLAB (EL 395'-0" & BELOW) TO BE 2'-0" RADIUS (MIN)

THIS DRAWING CONTAINS:
CONSTRUCTION CONTRACT NO. 255
CONSTRUCTION CONTRACT NO. 259
THE SCOPE OF THE 255 CONTRACT INCLUDES ALL EMBEDDED ELECTRICAL WORK IN REACTOR BUILDING.
THE SCOPE OF THE 259 CONTRACT INCLUDES THE INSTALLATION OF ELECTRICAL EQUIPMENT, RIGS, CABLE TRAYS, EXPOSED EQUIPMENT, GROUNDING TERMINATIONS & EXPOSED CONDUITS. FOR FURTHER DETAILS SEE CONSTRUCTION SPECS.

EBASCO
JUL 6 1981
CONSTRUCTION SITE

APPROVED FOR CONSTRUCTION

THIS DWG INCORPORATES ALL 413 CHANGE NOTICES RECEIVED AS OF 5-15-81

WPPS QUALITY CLASS II.G

PRC APERTURE CARD



NUCLEAR SAFETY RELATED
WASHINGTON PUBLIC POWER SUPPLY SYSTEM
NUCLEAR PROJECTS NO. 3 & 5
1981-1900 MW INSTALLATION
1903-1900 MW INSTALLATION
REACTOR BUILDING
CONDUIT & TRAY SECTIONS SH. 3

ALL DETAILS SHOWN ON THIS DRAWING WITHIN THE SCOPE OF THE CONTRACT SHALL BE INCLUDED IN THE CONTRACTOR'S BIDS PROPOSAL PRICE. THE USE OF TERMS SUCH AS "NOT RELEASED" SHALL NOT BE INTERPRETED AS BEING OUTSIDE THE CONTRACTOR'S SCOPE OF WORK.

NO.	DATE	REVISION	BY	CHK.	APPROVED
2	4-15-81	GENERAL REVISION	FL	GV	ED
1	3-20-80		LM	GV	ED
1	3-20-80		LM	GV	ED

DATE: 4-15-80
WPPS-3240
G-5336

RIDS

8303390563

