

NOTES:  
 1. PREFERRED ARRANGEMENT OF INSERTS ON PANEL SEE 314E133.  
 2. WINDOWS ON THIS SHEET ARE RESERVED FOR NSSS USE.  
 3. WINDOW NO. REF IS BY ROW, COLUMN FOR EXAMPLE IA, 3B, ETC...

	A	B	C	D	E	F	G	H	J	K	L	M
1	DIV 1 OR 4 DCS ELDI SW RINGS	DIV 2 OR 3 MHW ISLN SW RINGS		SC-LAB DIS VCL HOT DRAINED			CRD HYDR TEMP HI	ACCUMULATOR TROUBLE	DIV 1 RPT BYPASS	DIV 1 NS4/RPS SWSR CH BYP	NS-PS30 ANNUNCIATOR GRD FAULT	NS-PS30 LOSS OF DC PWR
2	DIV 1 TRIP OUT OF FILE OR PWR FAIL	DIV 2 TRIP OUT OF FILE OR PWR FAIL						ROD OUT BLOCK	DIV 2 RPT BYPASS	DIV 2 NS4/RPS SWSR CH BYP		
3	DIV 4 TRIP OUT OF FILE OR PWR FAIL	DIV 3 TRIP OUT OF FILE OR PWR FAIL					RC B PS TRIP	LG JAMES ALARM POINT	DIV 3 RPT BYPASS	DIV 3 NS4/RPS SWSR CH BYP		
4	DIV 1 LOGIC CARD OUT OF FILE	DIV 2 LOGIC CARD OUT OF FILE					ROD DRIFT		DIV 4 RPT BYPASS	DIV 4 NS4/RPS SWSR CH BYP		CONDENSER VACUUM LO
5	DIV 4 LOGIC CARD OUT OF FILE	DIV 3 LOGIC CARD OUT OF FILE					ROD OVERTRAVEL		DIV 1 OR 4 DNL PRESS LO	DIV 2 OR 3 DNL PRESS LO		STM BYP O PRESS RSLTH AID DISPLAYED

NO.	A	B	C	D	E	F	G	H	J	K	L	M
1	5-A	5-A		2-W			2-W	2-W	4-W	4-A	6-W	6-W
2	4-A	4-A					2-W	2-W	4-W	4-A		
3	4-A	4-A					2-W	2-W	4-W	4-A		
4	4-W	4-W					2-W		4-W	4-A		1-W
5	4-W	4-W					2-W		4-R	4-R		3-W

CHART EXAMPLES:  
 1-W-REF.DOC.1 - WHITE LENS.  
 3-R-REF.DOC.3 - RED LENS.

REFERENCE DOCUMENTS:  
 1. (C85-1050) STM BYP & PRS  
 2. (C11-1050) RC 3 15  
 3. (C94-1050) DCS (NUCLERET)  
 4. (C71-1050) RPS  
 5. (B21-1050) NSSS  
 6. NO REFERENCE DOCUMENTS (INTERNAL)

TERA  
 APERTURE  
 CARD

BALDWIN ASSOCIATES DCC  
 COPY # **IRU**  
 AUG 18 1981  
 FOR REFERENCE ONLY  
 Not To Be Used For Construction

REV	DATE	BY	CHKD	APP'D	DESCRIPTION
0	JUN 3 1980	AMK-0062			

  

NO.	DATE	BY	CHKD	APP'D	DESCRIPTION
1	JUN 3 1980	AMK-0062			

  

DESIGNED BY	DATE	BY	CHKD	APP'D	DESCRIPTION

  

DATE	BY	CHKD	APP'D	DESCRIPTION



RIDS

811100485

