



TABLE I

PART NO.	MARKING	MP ITEM NO.	CHAR SIZE
1000 A	(1) SSE SHELL (2) LEVEL	157	.12
B	(1) SSE SHELL (2) PRESSURE		
C	(1) SSE TUBE (2) PRESSURE		
D	(1) STEAM SEAL HDR (2) PRESSURE		
E	(1) SPE INLET (2) PRESSURE		
F	(1) LP TURB 1B STM (2) PRESSURE (3) UPSTREAM CIV 1		
G	(1) LP TURB 1A STM (2) PRESSURE (3) UPSTREAM CIV 2		
H	(1) LP TURB 1B STM (2) PRESSURE (3) UPSTREAM CIV 3		
1000 J	(1) LP TURB 1B STM (2) PRESSURE (3) UPSTREAM CIV 4	157	
1001 A	(1) MSR 1A SHELL (2) PRESSURE	157	
B	(1) MSR 1B SHELL (2) PRESSURE		
C	(1) MSR DRN TANK 1A (2) LEVEL		
D	(1) MSR DRN TANK 1B (2) LEVEL		
E	(1) RHTR DRN TANK 1A (2) LEVEL		
F	(1) RHTR DRN TANK 1B (2) LEVEL		
G	(1) X AROUND 1HS TO (2) AUX STM SYS (3) PRESSURE		
H	(1) MAIN CDSR VAC (2) PMP A CURRENT		
1001 J	(1) MAIN CDSR VAC (2) PMP B CURRENT	157	
1002	(1) MSR 1A LO PT DRN (2) VLV 1B21-CA-3	158	
1003	(1) MSR 1B LO PT DRN (2) VLV 1B21-CA-6		
1004	(1) MSR 1A LO PT DRN (2) VLV 1B21-CA-2		
1005	(1) MSR 1B LO PT DRN (2) VLV 1B21-CA-5		
1006	(1) MSR 1B DRN VLV (2) 1TD-MSR2		
1007	(1) MSR 1A DRN VLV (2) 1TD-MSR4	158	
1008	(1) AUX STM TO MSR 1A (2) INLET VLV 1B21-BSPV-1 (3) CLOSE (5) OPEN	159	
1009	(1) MS TO MSR 1A (2) INLET VLV 1B21-F302A (3) CLOSE (5) OPEN	159	
1010	(1) MSR 1A SCAVENGING (2) BLOCK VLV 1HD103A (3) CLOSE (5) OPEN	159	.12

GENERAL CLASSING
 112D2119
 INSERT P870-56B
 PART NAME: CLINTON T
 P. ISSUED

- NOTES:
- FOR ITEMS 2 THRU 130 SEE ELECTRICAL DEVICE LIST 442 X 663 6001 ITEM
 - FOR ITEMS 1, 151 THRU 499 SEE INSERT PARTS LIST 112D21196001.
 - FOR ITEMS 500 THRU 999 SEE HARDWARE LIST 442X610001, ITEM 155.
 - FOR ITEMS 1000 AND UP SEE MARKING TABLE I, THIS DRAWING. MARK PER PHOTO PROCESS SPEC 272A7128, ITEM 154.
 - THIS INSERT IS PART OF PGCC PANEL ASSY W13-P870.
 - FOR WIRING INFORMATION SEE CONNECTION DIAGRAM 93E174, ITEM 152.
 - MARK REF. DESIGNATIONS (REAR SIDE) ADJACENT TO DEVICES USING .12 HIGH CHARACTERS PER 175A7656 SYSTEM 154.
 - REF NO'S (1), (2), (3), (4), (5) ARE LINE NO'S PERTAINING TO MARKING SPEC.
 - WIRE LENGTH AND ROUTING TO BE DETERMINED BY MFG. AT ASSY.
 - DISCARD HARDWARE SUPPLIED WITH ITEM 104 AND REPLACE WITH HARDWARE AS SHOWN RESISTOR MFG TO BE PER 1580255, ITEM 160 FOR GAPING AND STRAIN RELIEF.

TABLE I

1011	(1) AUX STM TO MSR 1B (2) INLET VLV 1B21-BSPV-1 (3) CLOSE (5) OPEN	159	.12
1012	(1) MS TO MSR 1B (2) INLET VLV 1B21-F302B (3) CLOSE (5) OPEN		
1013	(1) MSR 1A LO PT DRN (2) VLV 1B21-CA-1		
1014	(1) MSR 1B LO PT DRN (2) VLV 1B21-CA-4		
1015	(1) MSR 1B DRN VLV (2) 1TD-MSR1 (3) CLOSE (5) OPEN		
1016	(1) MSR 1A DRN VLV (2) 1TD-MSR3 (3) CLOSE (5) OPEN		
1017	(1) MSR 1B SCAVENGING (2) BLOCK VLV 1HD103B (3) CLOSE (5) OPEN	159	.12

TERA
 APERTURE
 CARD

REDWAVE ASSOCIATES DCC
 COPY IPC
 AUG 18 1981
 FOR REFERENCE ONLY
 Not To Be Used For Construction

CONTROL ISSUE

REV	DATE	BY	CHKD BY	APPROVED BY	PRINTS TO
1	11-30-79	ALG	ALG	ALG	201A (3)
2	02-28-80	ALG	ALG	ALG	201A (3)
3	03-20-80	ALG	ALG	ALG	201A (3)
4	03-20-80	ALG	ALG	ALG	201A (3)

112D2119
 SAN JOSE
 2
 CI

61 W13-P870-56B

RIDS

8111100896

