

UNCLASSIFIED

PANEL PROVIDED WITH AUTOMATIC CKT INTERRUPTER PANEL NO. 1074 SERVICE WATER PUMP STRUCTURE
CHANNEL F

NO.	FRAME	TRIP	SIZE	DESTINATION	SCHEME CABLE NO.	SERVICE DESCRIPTION
01	100	30	2/C #10	1074101	0104001A	1074 VEST W/CEP
02	100	30	2/C #10		0104002A	SPARE
03	100	30	2/C #10		0104003A	
04	100	30	2/C #10		0104004A	
05	100	30	2/C #10		0104005A	
06	100	30	2/C #10		0104006A	
07	100	30	2/C #10		0104007A	
08	100	30	2/C #10		0104008A	
09	100	30	2/C #10		0104009A	
10	100	30	2/C #10		0104010A	
11	100	30	2/C #10	0100	010411A	SERVICE WTR. SYSTEM VALVES & PUMPS - CA
12	100	30	2/C #10		010412A	SPARE
13	100	30	2/C #10		010413A	
14	100	30	2/C #10		010414A	
15	100	30	2/C #10		010415A	
16	100	30	2/C #10		010416A	
17	100	30	2/C #10		010417A	
18	100	30	2/C #10		010418A	
19	100	30	2/C #10		010419A	
20	100	30	2/C #10	1064	010420A	MCC 1064 SPACE NTL.
21	100	30	2/C #10	1064	010421A	MCC 2064 SPACE NTL.
22	100	30	2/C #10	0104	010422A	MCC 0104 SPACE NTL.
23	100	30	2/C #10	0104	010423A	MCC 0104 SPACE NTL.
24	100	30	2/C #10		010424A	SPARE
25	100	15	2/C #10		010425A	
26	100	15	2/C #10		010426A	
27	100	15	2/C #10		010427A	
28	100	15	2/C #10		010428A	

UNCLASSIFIED WITH REV. 3-10-10, 24-28 DATE BY CHECKED DATE

SCALE: AS SHOWN DESIGNED: NEW DRAWN: SES DATE

ORIGIN: 120V AC DISTRIBUTION PANELS JOB NO. 220
MCC AND PLANT UNIT #2 DRAWING NO. 157
AND COAMM E-32(Q) SH. 34

TERA
APERTURE
CARD

16X

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to reprographics.

10-22-01 1007 Richard L. Thomas

R105

8111209866

