



56 PIPE DESIGN TABLE CHANGE TO BE MADE AT FIRST PIPE WELD OUTSIDE THE ESSENTIAL SERVICE WATER VALVE PITS.

97 FOR SCOPE OF INSTALLATION FOR OUTDOOR SX PIPE REFER TO M-066 SHTS 12,13,14,15.

98 1-3000 IS SW CONNECTION, CAPPED.

99 PIPE DESIGN TABLE CHANGE TO BE MADE AT FIRST PIPE WELD INSIDE OF AUXILIARY BUILDING.

PRC APERTURE CARD

NOTES

- ALL PIPING IS CATEGORY I QUALITY GROUP C, EXCEPT AS NOTED.
- ALL PIPING IS PER PIPING DESIGN TABLE 15.6.1, EXCEPT AS NOTED.
- SEE DRAWING M-02 FOR ESSENTIAL SERVICE WATER PUMP DRAINS.
- FLOW ELEMENT CLAMP MOUNTED SIGNAL TO BE SECURED TO THE SIDE OF THE INSTRUMENT OF IT-SX161.

ITEMS ARE SHOWN ON THIS DRAWING

FOR SAFETY CLASSIFICATION SYSTEM (CLASSIFICATION BOUNDARY DEFINITION ON DWG M-34 SHT 1)

NO.	DATE	BY	DESCRIPTION
1	11-1-82	[Signature]	ISSUED FOR INFORMATION PER DESIGN FREEZE
2	11-1-82	[Signature]	ISSUED FOR CONSTRUCTION

DATE	BY	DESCRIPTION
11-1-82	[Signature]	ISSUED FOR INFORMATION PER DESIGN FREEZE
11-1-82	[Signature]	ISSUED FOR CONSTRUCTION

DIAGRAM OF ESSENTIAL SERVICE WATER

MARBLE HILL NUCLEAR GENERATING STA UNITS 1 & 2

PUBLIC SERVICE INDIANA PLAINFIELD, INDIANA

PROJECT NUMBER: 480900

DRAWING NO: M-42

SHEET 1 OF 7

8305050425

RIDS

