



- NOTES:
1. VALVE SHALL HAVE HANDWHEEL FOR MANUAL CLOSING.
 2. UNLESS OTHERWISE INDICATED ALL PIPING SHOWN ON THIS DRAWING IS SAFETY CATEGORY II QUALITY GROUP D, AND PER THE REQUIREMENTS OF PIPING DESIGN TABLE 140BB.
 3. TO BE LOCATED OUTSIDE OF CURBICLE.
 4. ALL PIPING 2 1/2" AND LARGER SUPPLIED UNDER SPECIFICATION Y-2962 ALL PIPING 2" AND SMALLER SUPPLIED BY Y-2739. ALL PIPING INSTALLED BY SPEC Y-2739.
 5. 2" AND SMALLER PDI 150BB PIPING SHALL USE SOCKET WELDS ON VALVES ONLY IF THE VALVES HAVE SOCKET WELL END. ALL OTHER 155BB PIPING SHALL USE BUTT WELD JOINTS.

PRC APERTURE CARD

DRAWING RELEASE RECORD				DRAWING RELEASE RECORD			
REV	DATE	BY	DESCRIPTION	REV	DATE	BY	DESCRIPTION
1	12-22-77	...	FOR BID	1	12-22-77	...	FOR BID
2	12-22-77	...	FOR BID	2	12-22-77	...	FOR BID
3	12-22-77	...	FOR BID	3	12-22-77	...	FOR BID
4	12-22-77	...	FOR BID	4	12-22-77	...	FOR BID
5	12-22-77	...	FOR BID	5	12-22-77	...	FOR BID

DRAWING RELEASE RECORD				DRAWING RELEASE RECORD			
REV	DATE	BY	DESCRIPTION	REV	DATE	BY	DESCRIPTION
1	12-22-77	...	FOR FAB & CONSTR. PER SPEC Y-2739	1	12-22-77	...	FOR FAB & CONSTR. PER SPEC Y-2739
2	12-22-77	...	FOR FAB & CONSTR. PER SPEC Y-2739	2	12-22-77	...	FOR FAB & CONSTR. PER SPEC Y-2739
3	12-22-77	...	FOR FAB & CONSTR. PER SPEC Y-2739	3	12-22-77	...	FOR FAB & CONSTR. PER SPEC Y-2739
4	12-22-77	...	FOR FAB & CONSTR. PER SPEC Y-2739	4	12-22-77	...	FOR FAB & CONSTR. PER SPEC Y-2739
5	12-22-77	...	FOR FAB & CONSTR. PER SPEC Y-2739	5	12-22-77	...	FOR FAB & CONSTR. PER SPEC Y-2739

DIAGRAM OF WASTE DISPOSAL 30,000 GALLON RELEASE TANK

MARKET HILL NUCLEAR GENERATING STA. UNITS 1 & 2
PUBLIC SERVICE INDIANA
PLAINFIELD, INDIANA

M-48
31

SCALE: 1" = 10'

DATE: 12-22-77

BY: [Signature]

PROJECT: MARKET HILL NUCLEAR GENERATING STA. UNITS 1 & 2

11
9.8
11
17

11
9.8
11
17

8305060539

RIDS

