



- NOTES:
1. ALL INSTRUMENT AND EQUIPMENT NUMBERED TO BE PROVIDED WITH "SAFE-RECEIVE" MARKS A DIFFERENT PREPARE IS SHOWN. AN ASHTRAY TAG WILL REPLACE THE ASHTRAY TAG IN THE "SAFE-RECEIVE" EQUIPMENT OR INSTRUMENT NUMBER ARE A PART OF THE "SAFE-RECEIVE" SYSTEM.
 2. ALL PRESSURE TRANSDUCERS SHALL BE INSTALLED WITH PIPES AND VALVES IN CONFORMANCE WITH THE FOLLOWING:
 3. PIPING SHALL BE INSTALLED IN CONFORMANCE WITH THE FOLLOWING:
 4. ALL PIPING SHALL BE INSTALLED IN CONFORMANCE WITH THE FOLLOWING:
 5. ALL OTHER PIPING NOT COVERED IN CONCRETE ARE CL. 150.
 6. TEMPERATURE INDICATORS AND ELEMENTS ARE LOCATED IN THE FOLLOWING TANKS:
 7. STRAINERS TO BE OF OVER 200 MESH. PIECE INSTALLED FOR NORMAL OPERATION.
 8. FUEL POOL PURIFICATION PUMPS ARE SELF-VENTING.
 9. SAMPLE POINTS INSTALLED PER SPEC. 31178-0-248.
 10. THIS DRAWING INCLUDES THE FOLLOWING PUMP DRAWING: SYSTEMS 1178-FAC-04-16 TO 18.

TI
APERTURE
CARD

NOT TO BE USED FOR CONSTRUCTION
NUCLEAR SAFETY RELATED
QA CAT II

REV	DATE	DESCRIPTION	BY	CHKD	APP'D

9-1-6

MORTHEAST NUCLEAR ENERGY COMPANY
NORTHEAST UTILITIES

PIPING & INSTRUMENTATION DIAGRAM
FUEL POOL COOLING & PURIFICATION
SYSTEM

SCALE: AS SHOWN

DATE: 11/15/64

25212-0001

THE INFORMATION ON THIS DRAWING MAY NOT BE USED FOR REPAIR OR MAINTENANCE OF THE PLANT FACILITY UNLESS THE INFORMATION IS CORRECTED BY THE PLANT FACILITY MAINTENANCE MANUAL.

SCALE: AS SHOWN

DATE: 11/15/64

25212-0001

FOR NUCLEAR SAFETY RELATED QA CAT II

59

PDR RIDS

8406020146

