



- NOTES:
1. FOR GENERAL NOTES SEE DRAWING M-48, SHEET 1.
 2. PIPING ON THIS DIAGRAM IS 100BB UNLESS OTHERWISE SPECIFIED AS PIPING IS 100BB.
 3. PIPING ON THIS DIAGRAM IS SAFETY CATEGORY II QUALITY GROUP D.
 4. 1/2" INC. PIPE SHALL USE FIVE DIA. BENDS AND BUTT WELDS.



DRAWING RELEASE RECORD				DRAWING RELEASE RECORD			
REV.	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE	REV.	DATE
B	12-22-77	A. J. Wilson			FOR BID PER SPEC'S Y-2739 & Y-2962		
C	3-27-78	R. C. Wilson			GENERAL REVISION - FOR FAB & CONSTR. PER Y-2962 & CONSTA Y-2739		
D	12-24-80	R. C. Wilson			INCORP. BYRON REV. 12-22-80 (PARTIAL) - GENERAL REVISION - FOR FAB & CONSTR. PER SPEC Y-2739		
E	8-1-82	R. C. Wilson			GENERAL REVISION - FOR FAB & CONSTR. PER Y-2739 FOR RECORD Y-2962.		

SCALE: NONE

PROJECT NUMBER: 4923

DIAGRAM OF LIQUID RADWASTE EVAPORATOR SYSTEM MARBLE HILL NUCLEAR GENERATING STATION UNITS 1 & 2 PUBLIC SERVICE INDIANA PLAINFIELD, INDIANA

SHEET 9 OF 9

SARGENT & LUNDY CHICAGO

8305060602

RIDS

