



NOTES:
 3. FOR GENERAL NOTES SEE DRAWING M-48-SHT. 1
 4. PIPING ON THIS DIAGRAM IS SAFETY CATEGORY II QUALITY GROUP D UNLESS OTHERWISE NOTED.
 5. PIPING ON THIS DIAGRAM IS IN CONTACT WITH CONCENTRATES UNLESS OTHERWISE NOTED.
 6. 182BB AND 183BB PIPE IS IN CONTACT WITH CONCENTRATES.
 7. LINES OWX180A 1/2 & OWX233A-2 SH. LD. RISE AT LEAST 3 FEET ABOVE LINES OWX29AA, A3-1 1/2 BEFORE TURNING HORIZONTAL TO PREVENT BACKFLOW.

PRC APERTURE CARD

REV.	DATE	FIELD	PREPARED	REVIEWED	APPROVED	PURPOSE
A	5-21-79					
B	12-24-80					
C	2-1-82					

REV.	DATE	FIELD	PREPARED	REVIEWED	APPROVED	PURPOSE
A	5-21-79					
B	12-24-80					
C	2-1-82					

SCALE: NONE
 PROJECT NUMBER: 4808
 SHEET NUMBER: 1023

DIAGRAM OF LIQUID RADWASTE EVAPORATOR SYSTEM
 MARBLE HILL NUCLEAR GENERATING STA. UNITS 1 & 2
 PUBLIC SERVICE INDIANA
 PLAINFIELD, INDIANA

SARGENT & LUNDY
 CHICAGO

DRAWING NO. M-48
 SHEET 10B OF 11

17
 11
 8.5
 8.5
 11
 17

8305060615

RIDS

