


PRC APERTURE CARD

- NOTES:
1. BROKEN LINE PIPING SUPPLIED PER SPEC. Y-2762
  2. ALL SOLID LINE PIPING SUPPLIED AND INSTALLED PER SPEC. Y-2739
  3. FIELD ROUTED PIPING IN CONTACT WITH EVAPORATOR CONCENTRATES SHALL USE 5 DIAMETER BENDS AND BUTT WELDS.
  4. PIPING ON THIS DIAGRAM IS 400BB UNLESS OTHERWISE SPECIFIED.
  5. FOR GENERAL NOTES SEE DRAWING M-48, SHT.1.
  6. 1/2" O.D. PIPE IS SUPPLIED BY Y-2762
  7. PIPING ON THIS DIAGRAM IS SAFETY CATEGORY II QUALITY GROUP D.
  8. 182BB AND 182BB-1S IN CONTACT WITH CONCENTRATES

REV.	DATE	FIELD	PREPARED	REVIEWED	APPROVED	PURPOSE
A	12-22-77		J. J. Miller	J. J. Miller	J. J. Miller	FOR BIDS PER SPECS Y-2730 & Y-2952
B	01-21-79		J. J. Miller	J. J. Miller	J. J. Miller	GENERAL REVISION - FOR FAB & CONSTR PER SPEC Y-2762 & Y-2739
C	12-24-80		J. J. Miller	J. J. Miller	J. J. Miller	GENERAL REVISION - FOR FAB PER SPEC Y-2762 & CONSTR PER Y-2739
D	7-1-82		J. J. Miller	J. J. Miller	J. J. Miller	FOR INFORMATION Y-2838
E	7-1-82		J. J. Miller	J. J. Miller	J. J. Miller	GENERAL REVISION - FOR FAB PER SPEC Y-2762 & CONSTR PER SPEC Y-2739

REV.	DATE	FIELD	PREPARED	REVIEWED	APPROVED	PURPOSE
A	12-22-77		J. J. Miller	J. J. Miller	J. J. Miller	FOR BIDS PER SPECS Y-2730 & Y-2952
B	01-21-79		J. J. Miller	J. J. Miller	J. J. Miller	GENERAL REVISION - FOR FAB & CONSTR PER SPEC Y-2762 & Y-2739
C	12-24-80		J. J. Miller	J. J. Miller	J. J. Miller	GENERAL REVISION - FOR FAB PER SPEC Y-2762 & CONSTR PER Y-2739
D	7-1-82		J. J. Miller	J. J. Miller	J. J. Miller	FOR INFORMATION Y-2838
E	7-1-82		J. J. Miller	J. J. Miller	J. J. Miller	GENERAL REVISION - FOR FAB PER SPEC Y-2762 & CONSTR PER SPEC Y-2739



SCALE: NONE  
 PROJECT NUMBER: 4808  
 SHEET: 4923

DIAGRAM OF RADWASTE EVAPORATOR  
 MARBLE HILL NUCLEAR GENERATING STA. UNITS 1 & 2  
 PUBLIC SERVICE INDIANA, PLAINFIELD, INDIANA

DRAWING NO. M-48  
 SHEET 11B OF 118



RIDS

8305060622

