


PRC
APERTURE
CARD


- NOTES:
1. ALL SOLID LINE PIPING SUPPLIED & INSTALLED PER SPEC. Y-2739.
 2. BROKEN LINE PIPING SUPPLIED PER SPEC. Y-2762 AND INSTALLED PER SPEC. Y-2739.
 3. PIPING IN CONTACT WITH EVAPORATOR CONCENTRATES SHALL USE 5" DIAMETER BENDS AND BUTT WELDS.
 4. PIPING ON THIS DIAGRAM IS 140BB UNLESS OTHERWISE SPECIFIED.
 5. FOR GENERAL NOTES SEE DRAWING M-48, SHT. 1.
 6. 140BB PIPE IS SUPPLIED BY Y-2762.
 7. PIPING ON THIS DIAGRAM IS S-FETY CATEGORY II QUALITY GROUP C.
 8. 140BB AND 140BB IS IN CONTACT WITH CONCENTRATES.

DRAWING RELEASE RECORD				DRAWING RELEASE RECORD							
REV.	DATE FIELD	PREPARED	APPROVED	PURPOSE	FILE	REV.	DATE FIELD	PREPARED	APPROVED	PURPOSE	FILE
A	12-22-77	R. A. Nelson	J. C. Rowell	FOR BID PER SPECS Y-2739 & Y-2762							
B	5-21-79	R. A. Nelson	J. C. Rowell	GENERAL REVISION - FOR P&ID & CONSTR PER SPECS Y-2739 & Y-2762							
C	12-24-80	R. A. Nelson	J. C. Rowell	GENERAL REVISION - FOR P&ID & CONSTR PER SPEC Y-2762 & CONSTR PER Y-2739 FOR INFORMATION Y-2633							
D	2-1-82	R. A. Nelson	J. C. Rowell	GENERAL REVISION - FOR P&ID & CONSTR PER SPEC Y-2762 & CONSTR PER SPEC Y-2739 FOR INFO Y-2838							



SCALE
NONE
PROJECT NUMBER
4808
4923

DIAGRAM OF
RADWASTE EVAPORATOR
MARBLE HILL NUCLEAR
GENERATING STA UNITS 1 & 2
PUBLIC SERVICE INDIANA
PLAINFIELD, INDIANA



SARGENT & LUNDY
CHICAGO
DRAWING NO.
M-48
SHEET 13B OF

8305060641

RID's

