



DRAWING RELEASE RECORD				DRAWING RELEASE RECORD				REVISIONS		APPROVALS		SCALE		PROJECT		DRAWING NO.	
REV.	DATE	PREPARED	APPROVED	REV.	DATE	PREPARED	APPROVED	NO.	DESCRIPTION	BY	DATE	SCALE	PROJECT	DRAWING NO.	REV.	DATE	DESCRIPTION
C	12-24-80	M. A. Miller	J. W. Little														
D	07-27-81	M. A. Miller	J. W. Little														

P/R APERTURE CARD

- NOTES:
1. TYPICAL THESE LINES MUST BE LOCATED AT LOW POINT ON DISCHARGE HEADS TO BE LOCATED AS CLOSE TO THE WASTE MIXING TANKS AS PRACTICAL.
 2. PHYSICALLY LOCATE THE VALVE AS CLOSE TO THE END OF THE DISCHARGE HEADS AS POSSIBLE.
 3. DOWN CONNECTION MUST BE MADE AT TANK NOZZLES.
 4. SAFETY CLASSIFICATION CHANGE TO BE MADE AT TANK NOZZLES.
 5. FUTURE FLANGE FOR ADDITIONAL LEVEL INSTRUMENTS.
 6. TO BE INSTALLED OUTSIDE OF CUBICLE.
 7. FIELD ROUTED PIPING IN CONTACT WITH SPENT RESIN SHALL USE 3" DIAMETER BENDS.
 8. THIS IS TO BE LOCATED AS CLOSE TO THE WASTE MIXING TANKS AS PRACTICAL.
 9. FOR GENERAL NOTES SEE DWG. M-48 SHT. 1.
 10. PIPING ON THIS DIAGRAM IS 140BB UNLESS OTHERWISE SPECIFIED.
 11. PIPING ON THIS DIAGRAM IS SAFETY CATEGORY II QUALITY GROUP D.

NUCLEAR SAFETY RELATED ITEMS ARE SHOWN ON THIS DRAWING

DIAGRAM OF WASTE DISPOSAL RESIN REMOVAL

NO.	DESCRIPTION	DATE	BY
1	AS SHOWN		
2			
3			
4			
5			
6			
7			
8			
9			
10			

DIAGRAM OF WASTE DISPOSAL RESIN REMOVAL

MARBLE HILL NUCLEAR GENERATING STA UNITS 1 & 2 PUBLIC SERVICE INDIANA PLAINFIELD, INDIANA

DRAWING NO. M-48

SHEET 18 OF 36



8305060657

RIDS

