



- NOTES:
1. ALL VALVES AND INSTRUMENTS TO BE INSTALLED OUTSIDE CURBICLE.
  2. ALL ITEMS MARKED WITH ASTERISKS (\*) WILL BE SUPPLIED BY VENDOR AND INSTALLED PER SPEC. Y-2739.
  3. ALL PIPING 2 1/2" & OVER SUPPLIED PER SPEC. Y-2962 & INSTALLED PER SPEC. Y-2739.
  4. ALL PIPING UNDER 2 1/2" SUPPLIED & INSTALLED PER SPEC. Y-2739.
  5. PIPING ON THIS DIAGRAM IS 300# UNLESS OTHERWISE NOTED.
  6. PIPING TO THIS DIAGRAM IS SAFETY CATEGORY II QUALITY GROUP D.
  7. BREAK TO BE LOCATED AS CLOSE TO VALVE OXW076C AS IS PRACTICAL.

DRAWING RELEASE RECORD				DRAWING RELEASE RECORD			
REV.	DATE	FIELD	PREPARED	REVIEWED	APPROVED	PURPOSE	DATE
A	12-22-77					ISSUE FOR FAB.	12-22-77
B	6-21-79					EXTENSIVE GEN. REV. FOR FAB. PER Y-2962 & CONSTR. PER Y-2739.	6-21-79
C	8-10-79					GENERAL REVISION FOR FAB. PER SPEC. Y-2962 & CONSTR. PER Y-2739.	8-10-79
D	10-24-80					GENERAL REVISION FOR FAB. PER SPEC. Y-2962 & CONSTR. PER Y-2739.	10-24-80
E	07-27-81					INSTR. BYRON DRN MISC-100 - GENERAL REVISION FOR FAB. PER SPEC. Y-2962 & CONSTR. PER SPEC. Y-2739.	07-27-81
F	12-18-88					GEN. REVISION FOR SPEC. Y-2962 - FOR FABRICATION & CONSTR. Y-2739 FOR INFO Y-2702.	12-18-88

SCALE: NONE

DIAGRAM OF WASTE DISPOSAL BLOWDOWN MIXED BED DEMINERALIZER OC

MARBLE HILL NUCLEAR GENERATING STATION UNIT 1 & 2 PUBLIC SERVICE INDIANA PLAINFIELD, INDIANA

4808 4823

SAUBERT & LINDSEY

DRAWING NO. M-48

REV. F

SHEET 20A OF

8305060662

**RIDS**

