



- NOTES:
1. ALL INSTRUMENT AND EQUIPMENT HANGERS FOR CONDENSER DEMINERALIZED LIQUID WASTE SYSTEM TO BE REFINED WITH "P-100" EXCEPT WHERE A DIFFERENT PROFILE IS INDICATED.
  2. ALL PIPING CONNECTIONS MUST BE MADE WITH "P-100" UNLESS OTHERWISE NOTED.
  3. THE SYMBOL "E" IS ELECTRIC HEAT TRACER.
  4. INSTALL 3/8" DIA. PIPING PER SYSTEM BELONGING TO THIS SYSTEM UNLESS OTHERWISE NOTED.
  5. ALL "S-L" PIPING IS CL 150 UNLESS OTHERWISE NOTED.
  6. LIFTS TO A TEE TYPE STRAIN AND TO BE REMOVED AND REPLACED BY A SPOOL PIECE AFTER SYSTEM CLEAN-UP.
  7. REPLACE STRAIN WITH SPOOL PIECE AFTER SYSTEM CLEAN-UP.
  8. ALL INSTRUMENT AND EQUIPMENT HANGERS FOR CONDENSER DEMINERALIZED LIQUID WASTE SYSTEM TO BE REFINED WITH "P-100" EXCEPT WHERE A DIFFERENT PROFILE IS INDICATED.
  9. THIS DRAWING INCLUDES THE FOLLOWING Piping Diagram System: 150-150-10-1 TO 150-150-10-10 AND 150-150-10-11 TO 150-150-10-12.

NOT TO BE USED FOR CONSTRUCTION

QA CAT. 11

TI APERTURE CARD

9.2-6

NO.	DESCRIPTION	REV.	DATE
1	ISSUED FOR CONSTRUCTION	1	11/15/78

NORTHEAST NUCLEAR ENERGY COMPANY  
 A DIVISION OF  
 NORTHEAST UTILITIES

HILLSTONE NUCLEAR POWER STATION - UNIT 3  
 PIPING & INSTRUMENTATION DIAGRAM  
 CONDENSATE DEMINERALIZED LIQUID WASTE

DATE: 11/15/78  
 DRAWN BY: P. J. DAUGHERTY  
 CHECKED BY: P. J. LAM

25212-78000  
 S&W DWR NO 12179-F.11-123A-1



PDR RIDS

8406020197

