



- NOTES:
1. THE H<sub>2</sub> MANIFOLD SYSTEM SUPPLIED BY WESTINGHOUSE (CZ702) (DWG 275-XX-45447), SHIP ORDER #230 WILL NOT BE USED IN THE AUXILIARY BUILDING.
  2. ALL PIPING IN SIZES 2 1/2 AND LARGER SHALL BE FURNISHED UNDER SPEC Y-2962, UNLESS OTHERWISE NOTED.
  3. ALL PIPING IN SIZES 2" AND SMALLER SHALL BE FURNISHED UNDER SPEC Y-2739, UNLESS OTHERWISE NOTED.
  4. ALL PIPING SHALL BE INSTALLED UNDER SPEC Y-2739, UNLESS OTHERWISE NOTED.
  5. ALL PIPING ARE CLASS D WITH SEISMIC SUPPORTS AND IN ACCORDANCE WITH CHEMETRON REQUIREMENTS M-75.
  6. SPEC Y-2722 IS TO PROVIDE A TEMPORARY PIPE HEADER CAP, AS NOTED.

REV	DATE	BY	CHKD	DESCRIPTION
1	07-15-81	J. L. ...	...	...
2	...	...	...	...

**DIAGRAM OF CO<sub>2</sub> AND H<sub>2</sub> SYSTEM**

BYRON POWER PLANT UNITS 1 & 2  
MARBLE HILL NUCLEAR GENERATING STATION

DATE: 7-22-79  
DRAWN BY: SARGENT & LUNDY  
CHECKED BY: ...  
SCALE: NONE  
PROJECT NUMBER: 4300-00  
DRAWING NO: M-58  
SHEET: 1 OF 4

REV	DATE	BY	CHKD	DESCRIPTION
1	07-15-81	J. L. ...	...	...
2	...	...	...	...

**DIAGRAM OF CO<sub>2</sub> AND H<sub>2</sub> SYSTEM**

MARBLE HILL NUCLEAR GENERATING STATION UNITS 1 & 2  
PUBLIC SERVICE INDIANA  
PLAINFIELD, INDIANA

SCALE: NONE  
PROJECT NUMBER: 4300-00  
DRAWING NO: M-58  
SHEET: 1 OF 4

8305090336

RIDS

