



- NOTES
1. 15 SECONDS MINIMUM OPERATING TIME.
  2. PS 330-V CAN BE USED FOR 21" AND CORNER PIPING.
  3. TEMP. MARKINGS INSTALL A 100°F GASKET SEAL (TEMP. MARKINGS ARE ONLY TO BE USED FOR TESTING PURPOSES WHEN VALVES ARE BEING MANUALLY OPERATED). ALL PIPING AND NECESSARY SUPPORT WORK SHOULD BE COMPLETED BEFORE THE MAIN SYSTEM IS PLANNED CONNECTIONS AS SOON AS POSSIBLE. BLIND FLANGES SHALL BE INSTALLED UNTIL THE REDUCED SECTION IS COMPLETED.

5. DO NOT INSTALL DOWNSTREAM OF VALVE AND DRAIN VALVES. ALL LINE WORK INSIDE CONDENSER AND 11" STAINLESS-STEEL LAGGING INSIDE CONDENSER.

LINE LISTING	SIZE	CLASS	MATERIAL
02	3/4" (3/8" x 1/2")	100°F	CS
03	1" (3/4" x 1 1/4")	300°F	CS
04	1 1/2" (1 1/4" x 1 3/4")	180°F	CS
12	1 1/2" (1 1/4" x 1 3/4")	300°F	CS

APPROVED PRESSURE TOWER DESIGN - REV. 4 (COID-6-17-83)  
 CLEARED FOR PRESSURE BOUNDARY TESTING - REV. 3 (204-3-6-79)

SYSTEM CHANGE ORDER NUMBER: CH-1530-1.4-001

ISSUED ON: 10.4.7.5

DESIGNED BY: W. J. HARRIS

CHECKED BY: W. J. HARRIS

DATE: 10.4.7.5

SCALE: AS SHOWN

DWC No. CH-1530-1.4

TI APERTURE CARD

CONTROLLED COPY

Pressure Recovery  
 Files  
 (3-6-78)

10.4.7.5

8406270219

PDR RIDS

8406270219

