



TI APERTURE CARD

UNCONTROLLED  
JUN 25 1970  
COPY

- NOTES:
1. LOCATE VALVES ICFE, FID, ICF13 AS CLOSE TO THE COOLER AS POSSIBLE.
  2. CONSTRUCTION VENT OR DRAIN.
  3. VALVE CLOSURE ON FEEDWATER ISOLATION.
  4. DO NOT INSULATE DOWNSTREAM OF VENT AND DRAIN VALVES.
  5. PROVIDE INTERNAL INSULATION (C2) TO SPT FROM PIPING INTERSECTION.

LINE LISTING	PIPE SIZ.	PRESSURE	TEMPERATURE	CLASS	MATERIAL
CI	300.0	1400 PSIA	500°F	G	CS
CA	300.0	221 PSIA	500°F	G	CS

✓ CLEARED FOR PRESSURE BOUNDARY TESTING REV 5 (2006-4-4-78)

SYSTEM CHANGE ORDER NUMBER CH-1591-10-010

REVISION NO. 1 APPROVAL: [Signature] DATE: [Date]

CH-1591-10-010

DUKE POWER COMPANY  
CAMPBELL NUCLEAR STATION UNIT 1

FLOW DIAGRAM OF  
FEEDWATER SYSTEM  
(CF)

REVISION	DATE	BY	CHECKED	DATE	SCALE	DWG. NO.
1	10-4-7-10	[Signature]	[Signature]			CH-1591-10-010

10-4-7-10  
8406270231

PDR RIDS

8406270231

