



- NOTES:**
1. ALL WESTINGHOUSE FURNISHED VALVES (F-2702) INSTALLED WITH FLOW UNDER SEAT EXCEPT AS NOTED.
 2. ALL CHECK VALVES SHOULD BE "Y" TYPE LEFT CHECK.
 3. DELAY COIL - 40 FT. X 3/8" O.D. TUBING X 0.245" I.D. (PIPING SPACIALITY DATA SHEET S-CO077).
 4. ALL TUBING EXCEPT WHERE OTHERWISE INDICATED IS PER P.O.T. 1303-88.
 5. FOR DETAILS OF SAMPLE COOLER PANEL REFER TO (CONTRACT) P.O.D.W.G. NO. _____.
 6. LOCATE SAMPLE VALVE AS CLOSE TO PROCESS LINE AS POSSIBLE.

DRAWING RELEASE RECORD					DRAWING RELEASE RECORD				
REV	DATE	BY	REASON	APPROVED	REV	DATE	BY	REASON	APPROVED

DRAWING RELEASE RECORD					DRAWING RELEASE RECORD				
REV	DATE	BY	REASON	APPROVED	REV	DATE	BY	REASON	APPROVED
D	12-15-80	E.P. Hall	PREVIOUSLY RELEASED FOR FAB. & CONSTR. Y-2730						
E	03-03-81	E.P. Hall	INCLUDE BYRON REV. 1-30-80, Y-539-80 & O-641-80 FOR FAB. & CONSTR. PER SPEC. Y-2730						
F	08-25-81	E.P. Hall	INCLUDE BYRON REV. 10-15-80 FOR FAB. & CONSTR. PER SPEC. Y-2730						
F	01-25-83	E.P. Hall	INCLUDE BYRON REV. 12-10-82, 1-4-83, 4-8-81 - ADD UNIQUE FEATURES - TO P&ID FOR COMMENT						

SCALE	NONE
PROJECT NUMBER	1802900
DRAWING NO.	M-68
REVISION	J

DIAGRAM OF PROCESS SAMPLING (PRIMARY & SECONDARY)
MARBLE HILL NUCLEAR GENERATING STA UNIT 1
PUBLIC SERVICE INDIANA
PLAINFIELD, INDIANA

SARGENT & LUNDY
CHICAGO

8305090658

RIDS

