



SAFETY-RELATED
 ITEMS ARE SHOWN ON THIS DRAWING
 (PER SAFETY STANDARDS SYSTEM
 CLASSIFICATION/BOUNDARY DEFINITION ON
 DWG. U-3-8-1)

NOTE 1

NOTES:
 1. ALL PIPES ON THIS AREA ARE ONE INCH UNLESS OTHERWISE INDICATED.
 2. VALVE ACTUATED AUTOMATICALLY BY GAS ANALYZER.
 3. VALVE SUPPLIED BY WASTE GAS COMPRESSOR VENDOR.
 4. TRIPS CLOSED ON SIGNAL FROM RE-OIL.
 5. STARTS STANDBY WASTE GAS COMPRESSOR AT 2.0 PSIG.
 6. TYPICAL ARRANGEMENT FOR 100# CYLINDERS PER HEATER.
 7. TYPICAL ARRANGEMENT FOR 100# CYLINDERS PER HEATER.
 8. VALVE ACTUATED AUTOMATICALLY BY GAS ANALYZER.
 9. QUICK DISCONNECTS PIPED TO ACCOMMODATE O₂ SAMPLE VESSEL.
 10. OXYGEN, HYDROGEN & NITROGEN FOR GAS ANALYZER CALIBRATION TO BE SUPPLIED FROM BOTTLES.

PRC
 APERTURE
 CARD

REV	DATE	BY	CHKD	DESCRIPTION
1	1-10-78	J. J. [unclear]	[unclear]	DWG FOR COMMENT
2	1-17-78	[unclear]	[unclear]	DWG FOR COMMENT
3	1-24-78	[unclear]	[unclear]	DWG FOR COMMENT
4	2-1-78	[unclear]	[unclear]	DWG FOR COMMENT
5	2-8-78	[unclear]	[unclear]	DWG FOR COMMENT

REV	DATE	BY	CHKD	DESCRIPTION
1	1-10-78	J. J. [unclear]	[unclear]	DWG FOR COMMENT
2	1-17-78	[unclear]	[unclear]	DWG FOR COMMENT
3	1-24-78	[unclear]	[unclear]	DWG FOR COMMENT
4	2-1-78	[unclear]	[unclear]	DWG FOR COMMENT
5	2-8-78	[unclear]	[unclear]	DWG FOR COMMENT

DIAGRAM OF RADIOACTIVE WASTE GAS
 GENERATING STA UNITS 1 & 2
 PUBLIC SERVICE INDIANA
 PLAINFIELD, INDIANA

SARGENT & LUNDY
 CHEMICAL ENGINEERS

DRAWING NO. M-69
 SHEET 1 OF 3

REV	DATE	BY	CHKD	DESCRIPTION
1	1-10-78	J. J. [unclear]	[unclear]	DWG FOR COMMENT
2	1-17-78	[unclear]	[unclear]	DWG FOR COMMENT
3	1-24-78	[unclear]	[unclear]	DWG FOR COMMENT
4	2-1-78	[unclear]	[unclear]	DWG FOR COMMENT
5	2-8-78	[unclear]	[unclear]	DWG FOR COMMENT

DIAGRAM OF RADIOACTIVE WASTE GAS
 GENERATING STA UNITS 1 & 2
 PUBLIC SERVICE INDIANA
 PLAINFIELD, INDIANA

SARGENT & LUNDY
 CHEMICAL ENGINEERS

DRAWING NO. M-69
 SHEET 1 OF 3

8305090668

RIDS

