



SAFETY-RELATED ITEMS ARE SHOWN ON THIS DRAWING
 (FOR SAFETY CLASSIFICATION SEE SYSTEM CLASSIFICATION ON BOUNDARY DEFINITION ON DRAWING M-28 SHEET 1)

PRC
 APERTURE
 CARD

- NOTES:**
- UNLESS OTHERWISE INDICATED, ALL PIPING SHOWN IN THIS DRAWING IS SAFETY CATEGORY ID.
 - DRAIN VALVE IWE012 SHALL BE LOCATED AT EL. 350'-0" (APPROX). IF SPRAY ADDITIVE TANK RUPTURES, CURB IS DESIGNED TO CONTAIN ENTIRE VOLUME OF TANK. DRAINAGE SHALL BE BY OPERATOR TO A TEMPORARY HOLDING TANK.
 - 3/4" DRAIN LINE SHALL BE ROUTED INTO 2" EMBEDDED DRAIN.

REV	DATE	BY	CHKD	DESCRIPTION	FILE	REV	DATE	BY	CHKD	DESCRIPTION	FILE
A	10-18-78	A. C.						
B	11-20-78						
C	12-21-78						
D	1-23-79						
E	2-12-79						
F	2-12-79						

REV	DATE	BY	CHKD	PURPOSE	FILE	REV	DATE	BY	CHKD	PURPOSE	FILE
G	07-25-81	INCORP BYRON M-12 86-ADD & DELETE UNIQ FEAT--FOR FAB & CONSTR PER SPEC Y-2739 FOR RECORD Y-2962	...						
H	4-21-82	INCORP BYRON REV 11-14-81-ADD FOR M-0211--FOR FAB & CONSTR PER SPEC Y-2739 FOR RECORD Y-2962	...						

DIAGRAM OF AUXILIARY BUILDING EQUIPMENT DRAINS

PROJECT NUMBER: 4331
 SHEET NO: M-82
 DRAWING NO: M-82
 SHEET 2 OF 14

DIAGRAM OF AUXILIARY BUILDING EQUIPMENT DRAINS

MARBLE HILL NUCLEAR GENERATING STA UNITS 1 & 2
 PUBLIC SERVICE INDIANA
 PLAINFIELD, INDIANA

SCALE: NONE
 DATE: 11-28-78

0.5"
 11"

RIDS

8305090761

