



PRO APERTURE CARD

NUCLEAR SAFETY RELATED ITEMS ARE SHOWN ON THIS DRAWING FOR SAFETY CLASSIFICATION SEE SYSTEM CLASSIFICATION DEFINITION ON DWG M-34 SHEET 1

- NOTES
- UNLESS OTHERWISE INDICATED, ALL PIPING SHOWN ON THIS DRAWING IS SAFETY CATEGORY 1EO.
 - DRAIN VALVE 2WE012 SHALL BE LOCATED AT EL. 350'-0" (APPROX.) IF SPRAY ADDITIVE TANK RUSTURES. THE CURB IS DESIGNED TO CONTAIN ENTIRE VOLUME OF THE TANK. DRAINAGE SHOULD BE BY OPERATOR TO A TEMPORARY HOLDING TANK.

DRAWING RELEASE RECORD				DRAWING RELEASE RECORD			
REV	DATE	BY	CHKD	DESCRIPTION	REV	DATE	BY
1	11-15-76	A. Chagnon	J. Williams	FOR CONSTRUCTION			
2	12-22-77	A. Chagnon	J. Williams	FOR CONSTRUCTION			
3	01-25-78	A. Chagnon	J. Williams	FOR CONSTRUCTION			

DRAWING RELEASE RECORD				DRAWING RELEASE RECORD			
REV	DATE	BY	CHKD	DESCRIPTION	REV	DATE	BY
1	11-15-76	A. Chagnon	J. Williams	FOR CONSTRUCTION			
2	12-22-77	A. Chagnon	J. Williams	FOR CONSTRUCTION			
3	01-25-78	A. Chagnon	J. Williams	FOR CONSTRUCTION			

DIAGRAM OF AUXILIARY BUILDING EQUIPMENT DRAINS
 MARBLE HILL NUCLEAR GENERATING STA. UNITS 1 & 2
 PUBLIC SERVICE INDIANA
 PLAINFIELD, INDIANA

PROJECT NUMBER: 4391
 SHEET: 23 OF 28
 DATE: 12-22-77

BARRETT & LUNDY
 ENGINEERS
 CHICAGO, ILLINOIS

ROD ENRIQUEZ

30X

8305090768

RIDS

