



- NOTES
1. DISTRIBUTOR
 2. $\frac{1}{2}$ " EQUALIZER LINES.
 3. ALL HORIZONTAL REFRIGERANT SECTION PIPES SHALL BE SLOPED 1/8" IN THIS DIRECTION OF REFRIGERANT COMPRESSOR.

PRC APERTURE CARD

DRAWING RELEASE RECORD															
REV.	SPEC. NO.	DATE	DRAWN	CHECKED	DESIGN APPROVAL	DESCRIPTION	FIRM	REV.	SPEC. NO.	DATE	DRAWN	CHECKED	DESIGN APPROVAL	DESCRIPTION	FIRM
A	Y-2782	08-24-72	J. Palmer	M. B. Smith		RIS CONSTRUCTION									
B		02-08-80	J. Palmer	M. B. Smith		FOR CONSTRUCTION SPEC. Y-2782 FOR RECORD									

DRAWING RELEASE RECORD													
REV.	DATE HELD	PREPARED	REVIEWED	APPROVED	PURPOSE	FIRM	REV.	DATE HELD	PREPARED	REVIEWED	APPROVED	PURPOSE	FIRM
A	11-01-77	J. Palmer	M. B. Smith		BYRON REVA. 08-24-72 INITIAL ISSUE FOR BIDS PER SPEC. Y-2782								
A	12-22-77	J. Palmer	M. B. Smith		FOR BIDS PER SPEC. Y-2782 FOR INFORMATION SPEC. Y-2739, Y-2783 & Y-2790								
A	12-20-78	J. Palmer	M. B. Smith		FOR CONSTRUCTION SPEC. Y-2782 FOR INFORMATION SPEC. Y-2739, Y-2783 & Y-2790								
B	04-08-80	J. Palmer	M. B. Smith		BYRON REV. 08-05-80 INCORPORATED - MORE CONSTRUCTION SPEC. Y-2782 FOR INFORMATION								



PROJECT NUMBER: 4321M
 PROJECT TITLE: RADWASTE AND REMOTE CONTROL ROOM HVAC SYSTEM (VT) DIAGRAM
 DRAWING NO.: M-117
 SHEET 2 OF 3

SCALE: NONE
 PROJECT NUMBER: 4321M
 DRAWING NUMBER: M-117

DIAGRAM OF RADWASTE & REMOTE CONTROL ROOM HVAC SYSTEM (VT) MARBLE HILL NUCLEAR GENERATING STA. UNITS 1 & 2 PUBLIC SERVICE INDIANA PLAINFIELD, INDIANA

SARGENT & LUNDY ENGINEERS CHICAGO

30X

8305110544

RIDS

