



NO.	DATE	BY	DESCRIPTION
1	10/1/54
2	10/1/54
3	10/1/54
4	10/1/54
5	10/1/54

GENERAL NOTES:

- ALL DIMENSIONS SHOWN ON THIS DRAWING SHALL NOT BE USED FOR CONSTRUCTION.
- FOR ALL PENETRATIONS IN CEILING & FLOOR, SEE MECH., ELEC., PLUMBING & HVAC DRAWINGS.
- THE BEST DETAILS NOT INDICATED ON THIS DRAWING, SEE ROOF PLAN & DETAIL DRAWING, SEE 10-1-54.

GENERAL NOTES:

- ALL ARCHITECTURAL ITEMS SHOWN ON THIS DRAWING ARE NOT-NUCLEAR SAFETY RELATED UNLESS SPECIFICALLY NOTED FOR THE FOLLOWING ITEMS:
 - WATER TIGHT DOORS
 - MOVABLE RAISING DOOR
 - PROTECTIVE PAINT COATING

THE DRAWING SHOWS THE APPROXIMATE LOCATION AND NUMBER OF DETECTOR HEADS FOR DETAILS, SEE ELECTRICAL DRAWING NO. E-2024.

LEGEND

- 2 HOUR FIRE FLOOR
- 3 HOUR FIRE WALL
- 3 HOUR FIRE FLOOR
- 2 HOUR FIRE WALL
- 7 HOUR FIRE BREAK WALL
- WALL PENETRATION
- EXTERIOR WALL FIRE AREA BOUNDARY
- FIRE AREA BOUNDARY
- 3 HOUR FIRE BREAK WALL

FOR COMPLETE LEGEND SEE FHA-5

APERTURE CARD

NON-NUCLEAR SAFETY
 QA PROGRAM APPLICABLE
 CLASS. B SEISMIC CATEGORY II
 FIRE PROTECTION SYSTEM
 WASTE MANAGEMENT SYSTEM

TEXAS UTILITIES GENERATING CO.

FIRE HAZARD ANALYSIS
 CONTAINMENT/SAFEGUARD
 BUILDINGS UNIT AT
 FILL PLAN - EL. 073'-6"

FHA-5

REV.	DATE	APPROVED	DATE	REVISION
1	10/1/54
2	10/1/54
3	10/1/54
4	10/1/54
5	10/1/54

22"

17"

11"

8.5"

17"

22"

8408300288

PDR RIDS

