



NO.	REFERENCE DRAWING	DCCTEL	GE
1	PG 10, POST ACCIDENT SAMPLING SYSTEM	M-024-00-2	750922
2	LOGIC DIAGRAM, POST ACCIDENT SAMPLING SYSTEM	J-10-0	84

- NOTES:**
- REFER TO GE DRAWING 2001100-00 FOR DETAILS OF PENETRATIONS.
 - HEAT TRACES ON ALL GAS SAMPLE LINES BY DESIGNER (TYPICAL).
 - MULTIPOINT SAMPLE VALVE.
 - ALL STEELS WITHIN MANIFOLD BOUNDARY LINES SUPPLIED BY GE.
 - THE GE S&P NUMBER FOR THIS SYSTEM IS D 14.
 - THIS P&A CONTAINS SYSTEMS OR PORT-INS OF SYSTEMS:
 - AS-CLEAN WATER BRIMP STOP (TRANSFER)
 - BS-TRACER BOTTLE AND RECIRCULATION
 - DC-RESIDUAL WATER REMOVAL
 - EE-FORM WATER CLEANUP
 - EG-SAFETY (TURBINE AUX. COOLING)
 - FC-PROCESS SAMPLING
 - ALL EQUIPMENT AND INSTRUMENTS SHALL BE TAGGED FOR UNIT USE. ALL MANIFOLD VALVES AND PIPES WILL BE DESIGNATED AS COMMON.
 - PIPE AND FITTINGS SHALL BE QUALITY EXTRA STRONG (XAS).

FOR INFORMATION ONLY

TI APERTURE CARD

INCORPORATED DATE	BY	REVISION
2/14/75	W. J. H. / J. H. H.	1
REVISION PER	REVISION	REVISION
1. NO. FOR CONSTRUCTION	OPER. REVISION	OPER. REVISION
2. NO. FOR CONSTRUCTION	OPER. REVISION	OPER. REVISION
BEAVERT		
PUBLIC SERVICE ELECTRIC AND GAS COMPANY HOPE CREEK GENERATING STATION		
P&A		
POST ACCIDENT SAMPLING SYSTEM		
NO. 10	ENGINEER	DATE
NO. 10	IM-38-C	11/2/74

30 X 1

48 11
8.5
5
11
17

8409190307

PDR RIDS

