



NO.	LS	VALVE POSITION		FUNCTION	REFERENCE
		FULLY OPEN	FULLY CLOSED		
1				BYPASS	
2				SPARE	
3				GREEN LT	THIS DWG
4				OPEN LIMIT	
5				BYPASS	
6				SPARE	
7				SIGNAL ISOLATOR	E-11GC SH. 4
8				SPARE	
9				SPARE	
10				SPARE	
11				SPARE	
12				SPARE	
13				SPARE	
14				SPARE	
15				RED LT	THIS DWG
16				SPARE	

- NOTES
1. ALL EQUIPMENT LOCATED AT RESPECTIVE MCC EXCEPT AS NOTED
  2. APPLICABLE LOGIC DIAGRAM LSK-26-9
  3. CIRCUIT NO. TO PRECEDE WIRE NO.
  4. TORQUE SWITCHES TGS-O/TGS-C STOP MOTOR IF MECHANICAL OVERLOAD OCCURS DURING OPENING OR CLOSING CYCLE.
  5. FOR LOCATION REFERENCE SEE E-2B

NUCLEAR SAFETY RELATED

CS	CONT DET	DWG	SPARES
1-SISAS	"R"	E-3B	L3, R2

ELEMENTARY DIAGRAM-480V MCC CKTS  
 CHARGING PP TO HOT LEG ISOL VALVE  
 BEAVER VALLEY POWER STATION-UNIT 2  
 DUQUESNE LIGHT COMPANY  
 STONE & WEBSTER ENGINEERING CORPORATION  
 12241-E-60Z

NO.	DATE	BY	CHKD	REVISION
1	5/21/84	...	...	...
2	...	...	...	...
3	...	...	...	...
4	...	...	...	...
5	...	...	...	...
6	...	...	...	...
7	...	...	...	...

8409210307

T1  
 APERTURE  
 CARD

**PDR RIDS**

**8409210307**

