



ROTOR	LIMIT SWITCH CONTACT DEVELOPMENT				FUNCTION	REFERENCE
	FULLY OPEN	A	B	FULLY CLOSED		
1					BYPASS	
2					SPARE	
3					GREEN LT	THIS DWG
4					OPEN LIMIT	
5					BYPASS	
6					SPARE	
7					SIGNAL ISOLATOR	E-116K SH.4
8					SPARE	
9					SPARE	
10					SPARE	
11					SPARE	
12					SPARE	
13					SPARE	
14					SPARE	
15					RED LT	THIS DWG
16					SPARE	

- NOTES:
1. ALL EQUIPMENT LOCATED AT RESPECTIVE MCC EXCEPT AS NOTED
  2. APPLICABLE LOGIC DIAGRAM LSK-26-2
  3. CIRCUIT NO. TO PRECEDE WIRE NO.
  4. TORQUE SWITCHES TQS-O + TQS-C STOP MOTOR IF MECHANICAL OVERLOAD OCCURS DURING OPENING OR CLOSING CYCLE.
  5. FOR LOCATION REFERENCE SEE E-2B

**NUCLEAR SAFETY RELATED**

CS	CONT DET	DWG	SPARES
1-SISND	"R"	E-3B	L2,R2

ELEMENTARY DIAGRAM-480V PKC CKTS  
 SAFETY INJECTION SYSTEM VALVES  
 BEAVER VALLEY POWER STATION-UNIT 2  
 DUQUESNE LIGHT COMPANY  
 STORE & WEAVER ENGINEERING CORPORATION  
 12241-E-GR3

7/3/74	2/2/74	7/20/73	8/26/74	8/9/74	10-12-76	3-7-74
7/3/74	2/2/74	7/20/73	8/26/74	8/9/74	10-12-76	3-7-74
7/3/74	2/2/74	7/20/73	8/26/74	8/9/74	10-12-76	3-7-74

8409210309  
 TI  
 APERTURE  
 CARD



**PDR RIDS**

**8409210309**

