



ROW	LIMIT SWITCH CONTACT DEVELOPMENT					FUNCTION	REFERENCE
	LS	FULLY OPEN	A	B	FULLY CLOSED		
1						BYPASS	
2						SPARE	
3						GREEN LT	THIS DWG
4						OPEN LIMIT	
5						BYPASS	
6						SIGNAL ISOLATOR	E-HIGH SH-3
7						SPARE	
8						SPARE	
9						SPARE	
10							
11							
12							
13							
14						RED LIGHT	THIS DWG
15						SPARE	
16							

- NOTES:
1. ALL EQUIPMENT LOCATED AT RESPECTIVE MCC EXCEPT AS NOTED
 2. APPLICABLE LOGIC DIAGRAM LSK-26-1
 3. CIRCUIT NO. TO PRECEDE WIRE NO.
 4. TORQUE SWITCHES TGS-O & TGS-C STOP MOTOR IF MECHANICAL OVERLOAD OCCURS DURING OPENING OR CLOSING CYCLE.
 5. FOR LOCATION REFERENCES SEE E-25
 6. THIS CIRCUIT WAS PREVIOUSLY ON E-60K

NUCLEAR SAFETY RELATED

CS	CNT DET	DWG	SPARES
1-CHSBL	"2"	E-3B	L2, R2

ELEMENTARY DIAGRAM 480V MCC CKTS
 CHARGING PUMP DISCHARGE VALVE
 BEAVER VALLEY POWER STATION-UNIT 2
 DUQUESNE LIGHT COMPANY
 EVANS & KABOTER ENGINEERING CORPORATION

REV	DATE	BY	CHKD	APP	DESCRIPTION
1	8-3-74
2
3
4

12241-E-6UV

8409210319

TH APERTURE CARD

PDR RIDS

8409210319

